



Water Department Springbrook Treatment Plant Effluent

This report provides wastewater effluent for the Springbrook wastewater treatment plant.

All effluent is shown in Millions of Gallons (MG).

Data is updated monthly. The most recent data is from December.

[Learn more about Naperville's wastewater treatment plant.](#)

Year

2025



Maximum Effluent

45.93 MG on 8/20/2025

This is 83 % of the Design Max Flow

Minimum Effluent

12.40 MG on 2/22/2025

This is 22 % of the Design Max Flow

High Flow Days

1 days have been above 80% of the Design Max Flow

Daily Effluent

