
5-1E-2: AMENDMENTS TO THE ILLINOIS STATE PLUMBING CODE:

The Illinois State Plumbing Code, current edition, is hereby amended as it applies within the City of Naperville as follows:

Section 890.320 Types of Joints

l) This subsection is hereby amended as follows:

2. This subsection is deleted and replaced by the following text: Plastic pipe, joints and fittings made from polyethylene (PE), polyvinyl chloride (PVC), Chlorinated Polyvinyl Chloride (CPVC), or polybutylene (PB) made by either solvent-welded or fusion-welded connections, compression, or insert fittings, metal clamps and screws, or threaded joints shall be prohibited for water service or the domestic water distribution system of any building except for the distribution and conveyance of distilled or deionized water.

Section 890.610 General Requirements - Material and Design

This subsection is hereby amended as follows:

1. Pursuant to 17 Ill. Adm. Code 3730.307 (c) 4) and subject to the Illinois Plumbing Code (77 Ill. Adm. Code 890) and the Lawn Irrigation Contractor and Lawn Sprinkler System Registration Code (77 Ill. Adm. Code 892), be it hereby ordained that in the City of Naperville, all new plumbing fixtures and irrigation controllers installed after the effective date of this ordinance shall bear the WaterSense label (as designated by the U.S. Environmental Protection Agency WaterSense Program), when such labeled fixtures are available.

(Ord. No. 15-179, § 1, 11-17-2015; Ord. No. 18-032, § 1, 4-3-2018; Ord. No. 18-141, § 2, 12-4-2018)