

2025 DISTRIBUTION LEAKS

117

Water Loss	Total
Gallons	58,014,160
NRWL \$ Year to Date	\$ 326,164.41
Average Cost of Water Per Leak	\$ 2,787.73

Found by Acoustic Monitoring (AM)	4
Found by Leak Survey (LS)	10

Distribution Leaks By Pressure Zone	Total	%
Northwest	21	18%
Common	69	59%
East	9	8%
Northeast	13	11%
Southeast	1	1%

Distribution Leak Type	Total	%
Radial	35	30%
Hole	47	40%
Clamp	4	3%
Service	4	3%
Valve	9	8%
Corp	2	2%
Lateral	11	9%

Service Interruption Data	
Average Interruption (Minutes)	107
Total Customers Affected (2025)	1214
Average Customers Affected Per Interruption	10.4
% Customers Affected per Interruption	0.023%
% Customers Affected 2025	2.67%