

This report provides wastewater effluent for the Springbrook wastewater treatment plant.

All effluent is shown in Millions of Gallons (MG).

Data is updated monthly. The most recent data is from June.

[Learn more about Naperville's wastewater treatment plant.](#)

Year
 2024

Maximum Effluent
40.36 MG on 1/26/2024
This is 73 % of the Design Max Flow

Minimum Effluent
1.19 MG on 5/10/2024
This is 2 % of the Design Max Flow

High Flow Days
0 days have been above 80% of the Design Max Flow

