



## Legislation Details (With Text)

**File #:** 22-0686      **Version:** 1  
**Type:** Procurement Award      **Status:** Tabled  
**File created:** 5/26/2022      **In control:** City Council  
**On agenda:** 9/6/2022      **Final action:** 9/6/2022  
**Title:** Approve the award of Bid 22-180, Southwest Wastewater Pump Station Rehabilitation, to Integral Construction Inc. for an amount not to exceed \$1,332,000.00, plus a 3% contingency

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. WW034

Date	Ver.	Action By	Action	Result
9/6/2022	1	City Council	approved	
9/6/2022	1	City Council	tabled	Pass

### CITY COUNCIL AGENDA ITEM

#### **ACTION REQUESTED:**

Approve the award of Bid 22-180, Southwest Wastewater Pump Station Rehabilitation, to Integral Construction Inc. for an amount not to exceed \$1,332,000.00, plus a 3% contingency

**DEPARTMENT:** Water Utilities

**SUBMITTED BY:** Darrell Blenniss, Director

#### **BOARD/COMMISSION REVIEW:**

N/A

#### **BACKGROUND:**

The Southwest Wastewater Pump Station is located at 1870 Hassert Boulevard. The station was originally constructed in 1994. It originally included two (2) 77 HP submersible pumps with space provided for a third pump. A third smaller pump (58 HP) was added later as flow to the station increased. Since then, one of the two original pumps has failed beyond repair and was subsequently replaced. Currently all the pumps in the lift station are reaching the end of their service life and replacement is required.

In May 2022, the Water Utilities issued Bid 22-180, Southwest Wastewater Pump Station Rehabilitation. The rehabilitation work for this site includes the replacement of three (3) existing submersible sewage pumps, two (2) mixers in the wet well, guide rails and piping in the wet well; installation of VFD's for new pumps and mixers, and upgrades to the existing SCADA system. Work also includes associated conduits, wires concrete pad and earthwork.

#### **DISCUSSION:**

