



Legislation Details (With Text)

File #: 20-1082 **Version:** 1

Type: BID, RFP, RFQ, COOP, SOLE SOURCE, OPTION YEAR **Status:** Passed

File created: 9/15/2020 **In control:** City Council

On agenda: 10/6/2020 **Final action:** 10/6/2020

Title: Approve the award of Cooperative Procurement 20-352, Southeast Waterworks (SEWW), East Reservoir Roof Repair, to Garland DBS Inc. for an amount not to exceed \$240,000, plus a 5% contingency

Sponsors:

Indexes:

Code sections:

Attachments: 1. WU007

Date	Ver.	Action By	Action	Result
10/6/2020	1	City Council	approved	Pass

CITY COUNCIL AGENDA ITEM

ACTION REQUESTED:

Approve the award of Cooperative Procurement 20-352, Southeast Waterworks (SEWW), East Reservoir Roof Repair, to Garland DBS Inc. for an amount not to exceed \$240,000, plus a 5% contingency

DEPARTMENT: Water Utilities

SUBMITTED BY: Darrell Blenniss, Director

BOARD/COMMISSION REVIEW:

N/A

BACKGROUND:

The SEWW reservoirs were constructed in 1989 and include an intergovernmental agreement with the Naperville Park District, dated August 22, 1989. The Water Utilities reservoirs are located below tennis courts at 1699 Ranchview Drive. The agreement allows for both SEWW reservoirs to be used by park patrons to play tennis. It is the responsibility of the Water Utilities to maintain the reservoir structure for such use. It is the responsibility of the Naperville Park District to provide and maintain the tennis playing surface and accommodations.

After receiving complaints from residents about the condition of the tennis courts, City staff inspected the top sections of the reservoirs. The inspectors identified cracks and spalling of the visible sections of the reservoirs. Repairs to the reservoirs are imperative for preservation of structural integrity, water quality and the fire storage they possess for the City. The tennis courts are temporarily closed at this time.

DISCUSSION:

Staff identified an approved cooperative contract, Omnia Partners Cooperative PW1925 through Garland/DBS Inc., for procurement to refurbish the SEWW east reservoir roof that exhibits deep spalling and creates a hazardous condition. The east reservoir is one of two 3.0 million-gallon reservoirs located at SEWW.

The contractor will access the exterior top of the east reservoir, remove the existing surface of the reservoir roof, expose the substrate and repair any evident damage or failure. The contractor will remove and replace existing expansion joints and seal and recoat the entire surface. Following completion of the work, and after sufficient cure time, the Naperville Park District intends to resurface and stripe the tennis courts so they are available for use in 2021.

The completion date of this project is December 31, 2020.

FISCAL IMPACT:

CIP: WU007

Repairs to water reservoirs are expensed to the infrastructure account listed below, as part of the capital improvement program. A total of \$1 million is budgeted for miscellaneous waterworks improvements in 2020. The requested award is within budget

Account Number	Fund Description	Total Budget Amount
41251500-551502	Water & Wastewater	\$12,119,788

Per City Council directive, contingency on construction projects is set at 3% on projects over \$500,000 and 5% on projects under \$500,000