



Legislation Details (With Text)

File #: 20-552 **Version:** 1

Type: BID, RFP, RFQ, COOP, SOLE SOURCE, OPTION YEAR **Status:** Passed

File created: 5/5/2020 **In control:** City Council

On agenda: 5/19/2020 **Final action:** 5/19/2020

Title: Approve the award of Bid 20-172, Sanitary Sewer Manhole Rehabilitation, to Culy Contracting, LLC for an amount not to exceed \$141,947, plus a 5% contingency

Sponsors:

Indexes:

Code sections:

Attachments: 1. CIP Page

Date	Ver.	Action By	Action	Result
5/19/2020	1	City Council	approved	Pass

CITY COUNCIL AGENDA ITEM

ACTION REQUESTED:

Approve the award of Bid 20-172, Sanitary Sewer Manhole Rehabilitation, to Culy Contracting, LLC for an amount not to exceed \$141,947, plus a 5% contingency

DEPARTMENT: Water Utilities

SUBMITTED BY: Darrell Blenniss, Director

BOARD/COMMISSION REVIEW:

N/A

BACKGROUND:

The sanitary sewer manhole rehabilitation program began in 2000. The program is part of the Water Utilities' required IEPA CMOM (capacity, management, operations and maintenance) plan and IEPA required 10-year infiltration and inflow reduction program under Naperville's NPDES permit IL0034061. Over the past 20 years, the coating product has withstood winter freeze-thaw cycles without cracking. Water Utilities has successfully rehabilitated 1,424 manholes.

Naperville's proactive approach to combating infiltration and inflow (I&I) into the sanitary sewer system has yielded positive results. Since 1998, the population of Naperville increased by roughly 30,000 people or about 20%. However, the average amount of water treated at the Springbrook Water Reclamation Center decreased by roughly 18% <<https://data.naperville.il.us/City-Services/Springbrook-Water-Reclamation-Center-Average-Daily/ykaz-gn83>> over the same period.

The Water Utilities issued Bid 20-172 seeking a contractor to rehabilitate 47 existing sanitary sewer manholes, most of which are old brick or concrete block manholes. The bid specifications require installation of a non-cementitious coating to all interior surfaces including channel, bench, barrel,

cone and chimney sections of the manhole. The no-dig process creates a manhole liner that seals out stormwater induced infiltration and ground water inflow. The majority of manholes included in the bid are located north of 5th Avenue, south of Ogden Avenue and east of Washington Street.

DISCUSSION:

Advertisement Date:	04/22/2020	Notices Sent:	196
Opening Date:	05/07/2020	Planholders:	18
		Bids Received:	4

Bids were received from the following vendors:

VENDOR	COST AMOUNT
Cury Contracting LLC.	\$141,947
Michels Corporation	\$160,995
<i>Engineer's Estimate</i>	\$173,000
National Power Rodding Corporation	\$173,465
KIM Construction Company	\$224,705

FISCAL IMPACT:

CIP: WW006

Manhole rehabilitations are expensed to the infrastructure account listed below as part of the capital improvement program. A total of \$4,610,000 is budgeted for sanitary sewer system rehabilitations in 2020. The requested award is within budget.

Account Number	Fund Description	Total Budget Amount
41251500-551502	Water Utilities	\$12,119,788

Per Council directive, contingency on construction projects is set at 3% on projects over \$500,000 and 5% on projects under \$500,000.